


# FORM 10

Aon File Reference: BB012

<b>LISTING CERTIFICATE – SPRINKLER SYSTEM EQUIPMENT</b> As per section 1.16 of NZS 4541:2013 and NZS4515:2009 Appendix G		
This is to confirm that, on the basis of the information supplied in the application for listing of the equipment dated 29/02/2016 And additional information in May 2021 this organisation, as the nominated Sprinkler System Certifier considers that the appropriate requirements of NZS 4541:2020 and NZS4515:2009 have been adequately met with respect to the item described below, for use under the conditions set out on this certificate.		
Item: Pipe clamps		
For use as: Gravity pipe supports		
Certificate number BB012	Effective from 21 May 2021	
[REDACTED]		
Make: RSL		
Model: RSL18		
[REDACTED]		
Range limitations 50NB – 200NB		
Restrictions and warnings		
May be used at the maximum spacing distances as given in table 4.7 of NZS4541:2020.		
This listing is exclusively for use of the named products to be used as gravity hangers. The listing does not include their use as a component in a bracing system.		
Special conditions		
Signed 		Date 29 April 2022
Name IANZ Approved Signatory: Stephen Ridder	Designation Fire Protection Consultant	