


# FORM 10

Aon File Reference: BB013

<b>LISTING CERTIFICATE – SPRINKLER SYSTEM EQUIPMENT</b> As per section 1.16 of NZS 4541:2020 and NZS4515:2009 Appendix G	
This is to confirm that, on the basis of the information supplied in the application for listing of the equipment dated 29/02/2016 and supplementary information provided in May 2021 this organisation, as the nominated Sprinkler System Certifier considers that the appropriate requirements of NZS 4541:2020 and NZS4515:2009 have been adequately met with respect to the item described below, for use under the conditions set out on this certificate.	
Item: Pipe clamps	
For use as: Gravity pipe hangers	
Certificate number BB013	Effective from 21 May 2021
[REDACTED]	
Make: RSL	
Model: MRG, MRZ Range	
[REDACTED]	
Range limitations 21mm – 168mm OD (20nb – 150nb)	
Restrictions and warnings	
May be used at the maximum spacing distances as given in table 4.7 of NZS4541:2020.	
This listing is exclusively for use of the named products to be used as gravity hangers. The listing does not include their use as a component in a bracing system.	
Special conditions	
Signed 	Date 29 April 2022
Name IANZ Approved Signatory: Stephen Ridder	Designation Fire Protection Consultant