


FORM 10

Aon File Reference: BB015

LISTING CERTIFICATE – SPRINKLER SYSTEM EQUIPMENT As per section 1.16 of NZS 4541:2020 and NZS4515:2009 Appendix G	
This is to confirm that, on the basis of the information supplied in the application for listing of the equipment dated 06 May 2022 this organisation, as the nominated Sprinkler System Certifier considers that the appropriate requirements of NZS 4541:2020 and NZS4515:2009 have been adequately met with respect to the item described below, for use under the conditions set out on this certificate.	
Item: base plates	
For use as: Gravity pipe supports	
Certificate number BB015	Effective from 20 May 2022
[REDACTED]	
Make: MRZ & MRG	
Model: MRZ-BP10/M, MRZ-BP12/M, MRG-BP10/M, MRG-BP12/M	
[REDACTED]	
Range limitations M10 - 25 x 4 mm. M12 – 25 x 6mm.	
Restrictions and warnings	
May be used at the maximum spacing distances as given in table 4.7 of NZS4541:2020.	
This listing is exclusively for use of the named products to be used as gravity hangers. The listing does not include their use as a component in a bracing system.	
Special conditions	
Signed 	Date 20 May 2022
Name IANZ Approved Signatory: Stephen Ridder	Designation Fire Protection Consultant